

ČOV Lichkov 2018

datum odběru vzorku	teplota odpadní vody na odtoku (°C)	N-NH4 (mg/l) do 12°C (limit max. 10 mg/l)	N-NH4 (mg/l) nad 12°C (limit max. 40 mg/l)	Pcelk (mg/l) do 12°C (limit max. 3 mg/l)	Pcelk (mg/l) nad 12°C (limit max. 8 mg/l)
9.1.2018	7,1	0,29		1,56	
6.2.2018	6,2	1,30		1,77	
6.3.2018	6,4	19,37		0,85	
10.4.2018	7,7	11,47		0,44	
9.5.2018	12,0	4,52		4,29	
12.6.2018	15,2		0,90		2,12
10.7.2018	16,8		0,51		5,60
7.8.2018	18,3		1,36		3,77
10.9.2018	17,9		4,25		3,18
9.10.2018	15,5		1,12		1,01
6.11.2018	13,5		2,16		1,84
4.12.2018	10,5	11,81		3,37	
Ø hodnota za rok do 12°C		8,13		2,05	
Ø hodnota za rok nad 12°C			1,72		2,92