

ČOV Lichkov 2015

datum odběru vzorku	teplota odpadní vody na odtoku (°C)	N-NH4 (mg/l) do 12°C (limit max. 10 mg/l)	N-NH4 (mg/l) nad 12°C (limit max. 40 mg/l)	Pcelk (mg/l) do 12°C (limit max. 3 mg/l)	Pcelk (mg/l) nad 12°C (limit max. 8 mg/l)
14.01.2015	6,4	4,57		0,72	
11.02.2015	8,2	1,37		6,45	
09.03.2015	6,6	6,92		5,50	
14.04.2015	7,4	1,89		5,20	
18.05.2015	12,2		8,47		10,56
15.06.2015	15,3		0,65		9,70
30.07.2015	18,6		28,03		6,63
19.08.2015	17,3		5,60		4,13
15.09.2015	18,0		8,39		7,43
13.10.2015	16,5		8,34		10,29
11.11.2015	13,6		0,51		6,96
07.12.2015	9,3	6,91		1,51	
Ø hodnota za rok do 12°C		4,33		3,88	
Ø hodnota za rok nad 12°C			8,57		7,96